



ADDENDUM NO. 1

BID DOCUMENTS

March 1, 2022

PROJECT: EMERGENCY BACKUP GENERATORS TO SERVE MAGNOLIA STREET WELL AND NORTH PEACHTREE STREET WELL

GEFA Project No.: DWDRA20003

Still Waters Engineering Project No.: W0118.004

OWNER: City of Warwick

BID DATE: March 15, 2022 at 2:00 p.m.

1. BID DOCUMENTS – DRAWINGS – SHEET# E-2.1:

Revise the wording of ONE LINE DIAGRAM NOTE 2.,

which currently reads:

“CONTRACTOR SHALL FURNISH AND INSTALL A COMPLETE 100KW/125KVA(A), 480V, 3PH STANDBY DIESEL GENERATOR SET INCLUDING GENERATOR, GENERATOR CONTROL PANEL, MAIN CIRCUIT BREAKER, GENERATOR PAD, FUEL TANK RATED FOR 24 HR OF THE GENERATOR OPERATION AT 100% LOAD, FULL TANK OF DIESEL FUEL AND A NEMA 3R, SER AUTOMATIC TRANSFER SWITCH ATS-2. CONTRACTOR SHALL SUPPLY A LETTER OF GUARANTEE THAT THE SUBMITTED GENERATOR IS RATED TO START AND RUN THE FOLLOWING SPECIFIED LOADS:”

to now read:

“CONTRACTOR SHALL FURNISH AND INSTALL A COMPLETE 100KW/125KVA(A), 480V, 3PH STANDBY DIESEL GENERATOR SET INCLUDING GENERATOR, GENERATOR CONTROL PANEL, MAIN CIRCUIT BREAKER, GENERATOR PAD, FUEL TANK RATED FOR 24 HR OF THE GENERATOR OPERATION AT 100% LOAD, FULL TANK OF DIESEL FUEL AND A NEMA 3R, SER AUTOMATIC

TRANSFER SWITCH ATS-2. THE ATS CONFIGURATION SHALL BE AS SHOWN ON THE ONE LINE DIAGRAM E-2.1, DETAIL 1. THE TRANSFER SWITCH SHALL BE SERVICE ENTRANCE RATED WITH MAIN BREAKER ON UTILITY SIDE. MAIN CIRCUIT BREAKER FOR EMERGENCY POWER SHALL BE INCLUDED WITH THE GENERATOR, AS INDICATED ON THE DRAWING. CONTRACTOR SHALL SUPPLY A LETTER OF GUARANTEE THAT THE SUBMITTED GENERATOR IS RATED TO START AND RUN THE FOLLOWING SPECIFIED LOADS:"

END ADDENDUM NO. 1