



**ADDENDUM NO. 1**

**BID DOCUMENTS**

**March 5, 2020**

**PROJECT:** AMI Meter Upgrades – Divisions I & II

DWSRF 19-001

Still Waters Engineering Project No.: C2120.002

**OWNER:** City of Cuthbert

**BID DATE:** March 17, 2020 at 2:00 p.m.

**1. BID DOCUMENTS – AMI METERS & ACCESSORIES, SECTION 33125, PART 2 - PRODUCTS:**

Adding the following wording after Part 2 - Products, 2.8, E.:

**2.9 CURB STOP**

**A. Manufacturers:**

1. Mueller, Ford, or approved equal.
2. Substitutions: As specified in Section 016000 - Product Requirements

**B. Description:**

1. No Lead, brass body conforming to AWWA C800 (ASTM B584, UNS C89833).
2. 300 PSI working pressure.
3. Sized to match service tubing/pipe specified; inline configuration, angle valves not acceptable.
4. Valve must have padlock wing option.

**END ADDENDUM NO. 1**